

F-5-13



Mob.: 7970255060
9827878998

FIRE STOPPER

(FIRE SAFETY ENGINEER & CONTRACTOR)

Auth. Dealer Branded Companies (ISI Marked)
deals in : Fire Fighting Equipment & General Order Supplier

BUILDING FIRE SAFETY INSPECTION REPORT CARD

Date: 27/11/2020

This is to certify that we **M/s Fire Stopper** (Fire safety engineering & contractor) H-8 madhavnagar Gwalior (M.P.) Has Inspection and serviced the fire extinguisher for **kendriya vidyalayano. 3 morar cant GWALIOR MP**

Name of building	Date of inspection	Next due date of inspection	Capacity	Qut.	Type	Remark
k.v.no.3 Ground floor and First floor Chemistry lab Bio lab Computer lab library corridor office exit door store room	27/11/2019	26/02/2020	5kg	10nos	ABC	Ok
	N/A	N/A	5kg	10nos	ABC	N/A

Inspection of fire safety equipment checklist & summary :

Kendriya vidyalaya no.3 was surveyed for fire safety 27/11/2019 by m/s fire stopper.

Fire extinguishers have a crucial role in ensuring fire safety

safe lives or at least help to minimize unnecessary costs or other losses.

The purpose of this survey was to identify significant fire safety issue which will be further

1 fire extinguisher is in fully charged and tagged

2 pressure gauge is in the green area

3 fire extinguisher tags are current

4 the tags expires one year from date of inspection

5 parking area is safe zone

6 the building exit door are safe

All fire extinguisher are working condition and fully charged

Thanks

M/S Fire Stopper



H-8, Madhav Nagar Gwalior – 474002 (M.P.) Contact : 7024103403

E-mail : firestopper009@gmail.com